

COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Fixed Speed**

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: Hertz Kompressoren					
	Model Number: HDD 110	Date:	05.06.21			
2	X Air-cooled Water-cooled	Туре:	Screw			
	X Oil-injected Oil-free	# of Stages:	1			
	Rated Capacity at Full Load Operating					
3*	Pressure a, e	520,9	acfm ^{a,e}			
4	Full Load Operating Pressure b	175	b psig			
5	Maximum Full Flow Operating Pressure c	175	psig c			
6	Drive Motor Nominal Rating	150	hp			
7	Drive Motor Nominal Efficiency	96,2	percent			
8	Fan Motor Nominal Rating (if applicable)	3,82	hp			
9	Fan Motor Nominal Efficiency	55,7	percent			
10*	Total Package Input Power at Zero Flow ^e	44,1	kW ^e			
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	128,6	$k\mathbf{W}^{\mathrm{d}}$			
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure	24,7	kW/100 cfm ^e			
13	Isentropic Efficiency	72,5	Percent			

- a. Measured at the discharge terminal point of the compressor package in accordance with
- ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.

 b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
- on this dual stack.

 C. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
m ³ / min	ft3 / min	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	



Member

ROT 030.1

This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: