COMPRESSOR DATA SHEET

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Fixed Speed

1	Manufacturer: Hertz Kompressoren		
	Model Number: HDD 45	Date:	05.07.21
2	X Air-cooled Water-cooled	Type:	Screw
	X Oil-injected Oil-free	# of Stages:	1
	Rated Capacity at Full Load Operating		
3*	Pressure ^{a, e}	220,7	acfm ^{a,e}
4	Full Load Operating Pressure b	175	psig ^b
5	Maximum Full Flow Operating Pressure ^c	175	psig ^c
6	Drive Motor Nominal Rating	60	hp
7	Drive Motor Nominal Efficiency	94,5	percent
8	Fan Motor Nominal Rating (if applicable)	1,95	hp
9	Fan Motor Nominal Efficiency	73,1	percent
10*	Total Package Input Power at Zero Flow ^e	19,5	kW ^e
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure ^d	57,6	kW^d
12*	Specific Package Input Power at Rated	26,1	kW/100 cfm ^e
	Capacity and Full Load Operating Pressure ^e		KW/100 chil
13	Isentropic Efficiency	68,6	Percent

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>

NOTES:

CACI

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217 Appendix CEM is actual applied for par minute at inlat conditions
 - ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
 - c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.
- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Compressed Air & Gas Institute	Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	No Load / Zero Flow Power
	<u>m³ / min</u>	<u>ft3 / min</u>	%	%	
Member	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data