## **COMPRESSOR DATA SHEET**

In Accordance with Federal Uniform Test Method for Certain Lubricated Air Compressors

## **Rotary Compressor: Fixed Speed**

1	Manufacturer: Hertz Kompressoren		
	Model Number: HDD 90	Date:	05.07.21
2	X Air-cooled Water-cooled	Type:	Screw
	X Oil-injected Oil-free	# of Stages:	1
	Rated Capacity at Full Load Operating		
3*	Pressure <sup>a, e</sup>	440,4	acfm <sup>a,e</sup>
4	Full Load Operating Pressure b	175	psig <sup>b</sup>
5	Maximum Full Flow Operating Pressure <sup>c</sup>	175	psig <sup>c</sup>
6	Drive Motor Nominal Rating	125	hp
7	Drive Motor Nominal Efficiency	96,2	percent
8	Fan Motor Nominal Rating (if applicable)	3,82	hp
9	Fan Motor Nominal Efficiency	55,7	percent
10*	Total Package Input Power at Zero Flow <sup>e</sup>	37,0	kW <sup>e</sup>
11	Total Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>d</sup>	109,3	$kW^d$
12*	Specific Package Input Power at Rated Capacity and Full Load Operating Pressure <sup>e</sup>	24,8	kW/100 cfm <sup>e</sup>
13	Isentropic Efficiency	72,2	Percent

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: <u>www.cagi.org</u>

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217 A max C: ACEM is actual only fort par minute at inlat conditions
  - ISO 1217, Annex C; ACFM is actual cubic feet per minute at inlet conditions.b. The operating pressure at which the Capacity (Item 3) and Electrical Consumption (Item 11) were measured for this data sheet.
  - c. Maximum pressure attainable at full flow, usually the unload pressure setting for load/no load control or the maximum pressure attainable before capacity control begins. May require additional power.

No Load / Zero Flow

Power

- d. Total package input power at other than reported operating points will vary with control strategy.
- e. Tolerance is specified in ISO 1217, Annex C, as shown in table below:
- Volume Flow Rate at specified conditions
   Volume Flow Rate
   Specific Energy Consumption

   m³/min
   ft3/min
   %
   %

	<u>m<sup>3</sup> / min</u>	<u>ft3 / min</u>	%	%				
Member	Below 0.5	Below 17.6	+/- 7	+/- 8				
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6				
ROT 030.1	Above 15	Above 529.7	+/- 4	+/- 5				
		•		•				
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP_CAGI has not independently verified the reported data								