


## **COMPRESSOR DATA SHEET**

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR		
1	Manufacturer: Hertz Kompresso	ren	
2	Model Number: HVD 132	Date:	05.07.21
	X Air-cooled Water-cooled	Type:	Screw
	X Oil-injected Oil-free	# of Stages:	1
3	Rated Operating Pressure	125	$psig^b$
4	Drive Motor Nominal Rating	180	hp
5	Drive Motor Nominal Efficiency	96,4	percent
6	Fan Motor Nominal Rating (if applicable)	4,09	hp
7	Fan Motor Nominal Efficiency	55,7	percent
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	169,8	Max 833,8	20,36
	148,1	714,7	20,72
8*	126,2	607,4	20,78
	103,3	489,5	21,10
	91,1	408,3	22,31
	79,8	Min <b>289,9</b>	27,53
9*	Total Package Input Power at Zero Flow <sup>c</sup> ,	d 27,1	kW
10	Isentropic Efficiency	73,8	Percent
11	30,00		
	Specific Power 10'00 10'0 50'0 300 400 10'0 50'0 300 400		100 1000 1100 1200
	Note: Graph is only a visual Note: Y-Axis Scale, 10 to 35, + 5k'	neity (ACFM) representation of the data in Section 8 W/100acfm increments if necessary above 25% over maximum capacity	35

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program:



- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Compressed Air & Gas Institute

Volume Flow Rate			Specific Energy	
at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power
<u>m<sup>3</sup> /</u> <u>min</u>	ft³/min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1 12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data