


## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

MODEL DATA - FOR COMPRESSED AIR							
1	Manufacturer: Hertz Kompressoren						
2	Model Number: HVD 18	Date:	05.07.21				
	X Air-cooled Water-cooled	Type:	Screw				
	X Oil-injected Oil-free	# of Stages:	1				
3	Rated Operating Pressure	125	psig <sup>b</sup>				
4	Drive Motor Nominal Rating	25	hp				
5	Drive Motor Nominal Efficiency	93,7	percent				
6	Fan Motor Nominal Rating (if applicable)	1,66	hp				
7	Fan Motor Nominal Efficiency 50,5		percent				
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	23,0 Max	104,2	22,06				
0.*	20,3	91,2	22,23				
8*	16,4	76,3	21,49				
	14,1	58,8	23,91				
	11,2	43,0	26,09				
	7,9 Min	26,1	30,39				
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	2,7	kW				
10	Isentropic Efficiency	68,1	Percent				
11	35,00 30,00 30,00 25,00  15,00  10,00 0,0 25,0 50,0		0,0 125,0				
	_	Capacity (ACFM)  Note: Graph is only a visual representation of the data in Section 8					

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: NOTES:



- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

X-Axis Scale, 0 to 25% over maximum capacity

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate			Specific Energy	
at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1 2/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data