


## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

MODEL DATA - FOR COMPRESSED AIR							
1 Manufacturer: Hertz Kompressoren							
2	Model Number: HVD 45	Date:	05.07.21				
	X Air-cooled Water-cooled	Type:	Screw				
	X Oil-injected Oil-free	# of Stages:	1				
3	Rated Operating Pressure	100	psig <sup>b</sup>				
4	Drive Motor Nominal Rating	60	hp				
5	Drive Motor Nominal Efficiency	95	percent				
6	Fan Motor Nominal Rating (if applicable)	1,98	hp				
7	Fan Motor Nominal Efficiency	73,1	percent				
	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>				
	62,2 Max	310,9	20,00				
0.4	54,5	271,9	20,04				
8*	46,0	227,0	20,26				
	38,4	185,4	20,71				
	30,0	140,5	21,35				
	20,8 Min	91,8	22,66				
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	7,1	kW				
10	Isentropic Efficiency	66,5	Percent				
11	Сарас	0 175,0 200,0 225,0 250,0 275, ity (ACFM)					
	Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35						

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: NOTES:



- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

X-Axis Scale, 0 to 25% over maximum capacity

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

V	olume Flow Rate		Specific Energy	
at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1 12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data