


## **COMPRESSOR DATA SHEET**

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive** 

	MODEL DATA - FOR CO		
1	Manufacturer: Hertz Kompressore	n	
2	Model Number: HVD 7	Date:	05.07.21
	X Air-cooled Water-cooled	Туре:	Screw
	X Oil-injected Oil-free	# of Stages:	1
3	Rated Operating Pressure	100	psig <sup>b</sup>
4	Drive Motor Nominal Rating	10	hp
5	Drive Motor Nominal Efficiency	90,1	percent
6	Fan Motor Nominal Rating (if applicable)	0,22	hp
7	Fan Motor Nominal Efficiency	35,0	percent
0.1	Input Power (kW)	Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>
	10,5 Ma	x 45,7	23,00
	8,6	37,1	23,16
8*	7,7	33,1	23,23
	6,4	27,1	23,47
	4,9	20,1	24,19
	3,6 Mi	n 13,4	26,83
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>	1,2	kW
10	Isentropic Efficiency	57,8	Percent
11	Note: Graph is only a visua	25,0 pacity (ACFM)  I representation of the data in Secti	

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator e for a list of participants in the third party verification program: <a href="https://www.cagi.org">www.cagi.org</a>
a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; Consult CAGI website for a list of participants in the third party verification program: NOTES:



- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
  d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate			Specific Energy	
at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power
m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1 12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data