

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

	MODEL DATA - FOR		
1	Manufacturer: Hertz Kompres	ssoren	
	Model Number: IMPETUS VSI	Date:	12.18.23
2	X Air-cooled Water-cooled	ed Type:	Screw
	X Oil-injected Oil-free	# of Stages:	2
3	Rated Operating Pressure	100	psig ^b
4	Drive Motor Nominal Rating	50	hp
5	Drive Motor Nominal Efficiency	96,1	percent
6	Fan Motor Nominal Rating (if applicable)	n/a	hp
7	Fan Motor Nominal Efficiency	n/a	percent
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
	44,6	Max 271,2	16,46
0*	37,3	232,4	16,04
8*	30,5	188,6	16,19
	24,2	146,9	16,50
	18,3	105,6	17,34
	12,4	Min 62,5	19,79
9*	Total Package Input Power at Zero Flow ^{c, d}	5,6	kW
10	Isentropic Efficiency	80,8	Percent
11	25,00 25,00 (KW100 ACFM) 25,00 20,00 10,00	200 300	400
	Note: Graph is only Note: Y-Axis Scale, 10 to	Capacity (ACFM) a visual representation of the data in Section 35, +5kW/100acfm increments if necessary ale, 0 to 25% over maximum capacity	on 8

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator

Consult CAGI website for a list of participants in the third party verification program: NOTES:

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate			Specific Energy	
at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power
m ³ /min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.