

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

Manufacturer:	Hertz Kompressoren		
Model Number:	IMPETUS VSD 45	Date:	12.06.23
X Air-cooled	Water-cooled	Type:	Screw
X Oil-injected	Oil-free	# of Stages:	2
Rated Operating Pressure		150	psig ^b
Drive Motor Nominal Rating		60	hp
Drive Motor Nominal Efficiency		96,5	percent
Fan Motor Nominal Rating (if applicable)		n/a	hp
Fan Motor Nominal Efficiency		n/a	percent
Input Power (kW)		Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d
53,1	Max	250,0	21,24
45,1		225,3	20,04
38,3		179,4	21,36
31,3		145,8	21,43
25,3		104,2	24,33
21,4 Min		72,7	29,41
Total Package Input Power at Zero Flow ^{c, d}		6,4	kW
Isentropic Efficiency		77,9	Percent
35,00 Specific Power (RWInd ACFM) 20,00 Specific Power 20,00 Specific Po	•	• •	400
	Rated Operating Pressure Drive Motor Nominal Rating Fan Motor Nominal Rating Fan Motor Nominal Efficient Input Power 53,1 45,1 38,3 31,3 25,3 21,4 Total Package Input Power Isentropic Efficiency 40,00 35,00 40,00 20,00 15,00 10,00 0	Rated Operating Pressure Drive Motor Nominal Rating Drive Motor Nominal Efficiency Fan Motor Nominal Efficiency Input Power (kW) 53,1 Max 45,1 38,3 31,3 25,3 21,4 Min Total Package Input Power at Zero Flow ^{c, d} Isentropic Efficiency Isentropic Efficiency Mote: Graph is only a visual report of the Note: Y-Axis Scale, 10 to 35, +5 kW	Rated Operating Pressure

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator



www.cagi.org

a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.

ACTM is actual cutoff eet per immute at miner continuous.

The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

C. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Compressed Air & Gas Institute

Vo	olume Flow Rate		Specific Energy	
at sp	ecified conditions	Volume Flow Rate	Consumption	No Load / Zero Flow Power
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1 12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.