

## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

	MODEL DAT		PRESSED AIR			
1	Manufacturer: Hertz	Kompressoren				
2	Model Number: IMPE	el Number: IMPETUS VSD 75		12.18.23		
	Air-cooled X V	Vater-cooled	Type:	Screw		
	X Oil-injected Oil-free		# of Stages:	2		
3	Rated Operating Pressure	Operating Pressure		psig <sup>b</sup>		
4	Drive Motor Nominal Rating	Notor Nominal Rating		hp		
5	Drive Motor Nominal Efficiency	e Motor Nominal Efficiency		percent		
6	Fan Motor Nominal Rating (if app	Fan Motor Nominal Rating (if applicable)		hp		
7	Fan Motor Nominal Efficiency	Motor Nominal Efficiency		percent		
	Input Power (kW)		Capacity (acfm) <sup>a,d</sup>	Specific Power (kW/100 acfm) <sup>d</sup>		
	88,0 Max		448,8	19,62		
	73,4		388,1	18,92		
8*	59,4		306,9	19,36		
	46,9		230,6	20,33		
	34,9		147,3	23,71		
	30,6 Min		119,7	25,56		
9*	Total Package Input Power at Zero Flow <sup>c, d</sup>		7,8	kW		
10	Isentropic Efficiency		84,3	Percent		
11			300 400 y (ACFM)			
		Note: Graph is only a visual representation of the data in Section 8  Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm increments if necessary above 35  X-Axis Scale, 0 to 25% over maximum capacity				

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Member								
	Volume Flow Rate			Specific Energy				
	at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power			
	m <sup>3</sup> / min	ft <sup>3</sup> / min	%	%	%			
	Below 0.5	Below 17.6	+/- 7	+/- 8				
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%			
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%			
ROT 031.1	Above 15	Above 529.7	+/- 4	+/- 5				
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.								