

COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR							
Manufacturer: Hertz Kompressoren							
Model Number: IMPETUS VSD 110	Date:	04/25/23					
Air-cooled X Water-cooled	Type:	Screw					
X Oil-injected Oil-free	# of Stages:	2					
Rated Operating Pressure	100	psig ^b					
Drive Motor Nominal Rating	150	hp					
Drive Motor Nominal Efficiency	96.5	percent					
Fan Motor Nominal Rating (if applicable)	N/A	hp					
Fan Motor Nominal Efficiency	N/A	percent					
Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
136.7 Ma	x 816.3	16.75					
115.2	700.9	16.43					
96.3	593.8	16.22					
76.8	472.2	16.27					
60.1	359.4	16.71					
41.8 M	n 239.5	17.48					
Total Package Input Power at Zero Flow ^{c, d}	17.2	kW					
Isentropic Efficiency	79.4	Percent					
Note: Graph is only a visual Note: Y-Axis Scale, 10 to 35, + 5k	epresentation of the data in Section V/100acfm increments if necessary abo	8					
	Manufacturer: Hertz Kompressoren Model Number: IMPETUS VSD 110 Air-cooled X Water-cooled X Oil-injected Oil-free Rated Operating Pressure Drive Motor Nominal Rating Drive Motor Nominal Efficiency Fan Motor Nominal Efficiency Input Power (kW) 136.7 Ma: 115.2 96.3 76.8 60.1 41.8 Min Total Package Input Power at Zero Flow ^{c, d} Isentropic Efficiency 30.00 25.00 15.00 Note: Graph is only a visual results of the context of the c	Manufacturer: Hertz Kompressoren					

^{*}For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
 d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
- NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Compressed Air & Gas Institute

Volume Flow Rate		olume Flow Rate		Specific Energy	
at specified conditions		pecified conditions	Volume Flow Rate	Consumption	No Load / Zero Flow Power
<u>m³ / 1</u>	min_	ft ³ / min	%	%	%
Below	0.5	Below 17.6	+/- 7	+/- 8	
0.5 to	1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to	15	53 to 529.7	+/- 5	+/- 6	
Abov	e 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data