

## **COMPRESSOR DATA SHEET**

## In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

			DATA - 1									
1	Manufacturer:		Hertz Kom	press	oren							
	Model Number:		IMPETUS	VSD	110			Date	:	04	4/25/23	
2	Air-c	Air-cooled X Water-cooled				Type:			:	Screw		
	X Oil-in	njected	Oil-fre	ee			# o	f Stages	:		2	
3	Rated Operating	erating Pressure						125			psig <sup>b</sup>	
4	Drive Motor Non	tor Nominal Rating					150			hp		
5	Drive Motor Non	tor Nominal Efficiency					96.5			percent		
6	Fan Motor Nomi	otor Nominal Rating (if applicable)					N/A			hp		
7	Fan Motor Nomi	Nominal Efficiency N/A						percent				
	Input Power (kW)					Capacity (acfm) <sup>a,d</sup>			Specific Power (kW/100 acfm) <sup>d</sup>			
	138.8	3			Max	Date: Type: # of Stages:  125 150 96.5 N/A N/A Capacity (acfm) <sup>a,d</sup> Iax 751.8 643.0 553.2 441.0 345.5 Iin 237.9 17.2 81.4			18.46			
8*	117.4					643.0			18.26			
8.		99.8					553.2		<u> </u>	18.03		
	80.9				441.0			18.33				
	64.9				345.5			18.78				
	47.1 Min				237.9				19.81			
9*		ackage Input Power at Zero Flow <sup>c, d</sup>								kW		
10	Isentropic Efficie	ncy					81.4 Perc		Percent			
11	Specific Power (kW/100 ACFM)	25.00	100 200  Note: Graph Note: Y-Axis Sca		visual rep	y (ACFM oresentati	I) on of the	data in Sect	ion 8	900	1000	
		:	Note: Y-Axis Sca	le, 10 to 3	visual rep 5, + 5kW/	resentati 100acfm i	on of the	if necessary		35		

\*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.



Member

Vo	lume Flow Rate		Specific Energy		
at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Powe	
$\underline{m}^3 / \underline{min}$	ft <sup>3</sup> / min	%	%	%	
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7		
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%	
Above 15	Above 529.7	+/- 4	+/- 5		