COMPRESSOR DATA SHEET

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive**

	•	DATA - FOR COM							
1	Manufacturer: Hertz Kompressoren								
2	Model Number:	IMPETUS VSD 250	Date:	04/25/23					
	Air-cooled	X Water-cooled	Type:	Screw					
	X Oil-injected	Oil-free	# of Stages:	2					
3	Rated Operating Pressure		100	psig ^b					
4	Drive Motor Nominal Ratir	ıg	335	hp					
5	Drive Motor Nominal Effic	eiency	97	percent					
6	Fan Motor Nominal Rating	(if applicable)	N/A	hp					
7	Fan Motor Nominal Efficie	ncy	N/A	percent					
	Input Powe	r (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d					
	299.2	Max	1845.3	16.21					
8*	254.7		1599.9	15.92					
8.	212.2		1347.3	15.75					
	178.2		1114.4	15.99					
	139.2		857.9	16.23					
	101.4	Min	603.9	16.80					
9*	Total Package Input Power	at Zero Flow ^{c, d}	45.0	kW					
10	Isentropic Efficiency		82.0	Percent					
11	30.00 25.00 25.00 25.00 20.00 15.00 10.00 0	Note: Graph is only a visual rep Note: Y-Axis Scale, 10 to 35, + 5kW/1	1000 1200 1400 160 y (ACFM) resentation of the data in Section 00acfm increments if necessary abo 6 over maximum capacity	8					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator Consult CAGI website for a list of participants in the third party verification program: www.cagi.org



a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions. b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.

c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,

manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

	Volume Flow Rate			Specific Energy			
	at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power		
	<u>m³/min</u>	<u>ft³ / min</u>	%	%	%		
	Below 0.5	Below 17.6	+/- 7	+/- 8			
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%		
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%		
ROT 031.1	Above 15	Above 529.7	+/- 4	+/- 5			
12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data							