
## **COMPRESSOR DATA SHEET**

In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors **Rotary Compressor: Variable Frequency Drive** 



a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E; ACFM is actual cubic feet per minute at inlet conditions.



b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,



- manufacturer may state "not significant" or "0" on the test report.

d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:

NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member					
	Volume Flow Rate			Specific Energy	
	at specified conditions		Volume Flow Rate	Consumption	No Load / Zero Flow Power
	$\underline{m^3} / \underline{min}$	$ft^3 / min$	%	%	%
	Below 0.5	Below 17.6	+/- 7	+/- 8	
	0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
	1.5 to 15	53 to 529.7	+/- 5	+/- 6	
ROT 031.1	Above 15	Above 529.7	+/- 4	+/- 5	
12/19 Rev 3 This form w	as developed by the	Compressed Air and Gas Institute f	or the use of its members par	ticipating in the PVP. CAGI has r	ot independently verified the reported d